

Important Information about your Drinking Water

Walworth Waterworks Failed to Take Corrective Action following identification of a Significant Deficiency

Deficiencies or circumstances requiring corrective action by us to better ensure a safe supply of water for human consumption were previously identified in our water system. We failed to address the significant deficiencies in accordance with a schedule we agreed to follow. The deficiencies included:

Modify overflows on the Main Street Tower to be in compliance with NR 811.64(4).

What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches. Significant deficiencies include defects in the design, operation, or maintenance of a public water system, or a failure or malfunction of the water source(s), treatment, storage or distribution system that can cause the introduction of contamination into the water delivered to you, our consumers, or when a health risk exists to consumers of the water.

What is being done to correct the problem?

Corrective action(s) taken: _____

We have corrected the significant deficiency(ies). This public notice serves to inform you that significant deficiencies were identified and that we did not correct them in a timely manner.

The corrective actions made include(ed): _____

If you have questions regarding the safety of our drinking water, please contact:

Tim Boss, Public Works Director

262-275-6648

Name of Responsible Person

Area Code-Telephone Number

131 Badger Street

Walworth

WI

53184

Street Address


City

State

Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.

X



Signature

6-30-2021

Date

Tier 2 Notice

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Requirements Not Met for Walworth Waterworks**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. Between 07/01/2020 and 10/31/2020, we did not monitor for **lead and copper contaminants, and therefore cannot be sure of the quality of your drinking water during that time.**

What precautions should be taken at this time?

There are no special precautions you need to take at this time. However, it is important to remember that the quality of your drinking water is not known at this time.

What was the cause of the missed monitoring requirements?

The Wisconsin Department of Natural Resources(DNR) did not provide a list of acceptable sampling sites.

What is being done to correct the problem?

While the water utility has contacted the DNR, the utility has still not received a list of approved sampling sites.

When will the problem be resolved?

Testing will be done as soon as the water utility receives an approved list of sampling sites from the DNR.

If you have questions regarding the safety of our drinking water, please contact:

Tim Boss, Public Works Director
Name of Responsible Person

262-275-6648
Area Code-Telephone Number


131 Badger Street
Street Address

Walworth
City

WI 53184
State Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.

X



Signature

6-30-2020

Date